





# Wind power based pumped storage on Suðuroy

Franziska Ludescher-Huber, Norconsult

# Background



Suðuroy on the Faroe islands: 5000 inhabitants.



# Background



Power consumption has increased due to a fish processing factory. Power consumption earlier: 3 MW Power consumption expected: 8 MW



# **Power production today**



Botní hydropower plant (1,1 MW + 2,2 MW) Vágur power plant (heavy fuel oil; 2,7 MW + 2,7 MW + 4,15 MW)







Main questions to be answered:

- Cost of investment for a new pumped storage power plant?
- How much more renewable energy can be produced with a pumped storage plant?

Presumption:

A 10 MW wind farm is going to be installed on Suðuroy.

# **Hydro Power**





# Status quo





### **Pumped storage power plant**





**Costs of investment** 

Pumped storage plant : 105 mill. NOK (2,5 MW turbine and 4 x 1,25 MW pumps)

10 MW wind turbines 80 mill. NOK











# **Simulation input - consumption**



#### **Power consumption** (hourly data for one modell future year)

Strong variations

- daytime variation
- fish processing factory



As the fish processing factory just had started producing, it was not possible to use empirical values. Jarðfeingi constructed a modell year based on different sources, which was used for the simulations.



6 years of wind data for Suðuroy (2007-2012) were made available and were used to calculate the power output of the wind turbines.





# **Simulation input - wind data**



Inflow data for the reservoirs Miðvatn and Vatnsnes:

Daily inflow over a 11 year period (2002-2012). Basic data provided by SEV, adapted by Norconsult.





### Simulation period: each hour from 1.1.2002 - 31.12.2012

Simulation rules:

- Wind power that meets the consumption is used directly
- "Excess wind power" is used for pumping (if the upper reservoir is not full).
- If there is too little wind power -> the turbine of the pumped storage plant starts.
- The program optimizes the operation of the pumped storage plant and the hydropower production in Botní.
- optimization for reservoir levels/volumes in order to maximize total production of renewable energy
- In situations where demand exceeds the production from wind and hydropower the model assumes additional supply from another source of power.

## Results



With 10 MW of wind power installed on Suðuroy and with a new pumped storage plant, the island can be supplied with more than 80% renewable energy: 65 % wind power (meeting the demand directly) 18,5 % hydro power (including from pumped storage) 16,5 % must be imported from the main grid or be produced by other means.

			+ 25% turbine capacity and
Production	Base case	+ 25% turbine capacity	larger upper reservoir
	GWh	GWh	GWh
Wind power production (used for general consumption and pumping)	34,3	34,6	34,9
Hydropower production (pumped storage and Vatnsnes branch in Botni)	8,6	8,8	9,0
Hydropower production (Ryskivatn branch in Botni)	1,2	1,2	1,2
Total hydropower	9,8	10,0	10,2
Wind-and hydropower available	44,1	44,6	45,1
Fuel based power production or import from main grid	8,8	8,6	8,4
Total power production	52,9	53,2	53,5
Consumption			
	GWh	GWh	GWh
General consumption	45,8	45,8	45,8
Pumping energy	7,1	7,4	7,7
General consumption and pumping	52,9	53,2	53,5
Surplus wind power production (no demand on Suðuroy)	5,0	4,7	4,4

### Results







Production method	Price DKK/kW el	Comment
Heavy fuel oil based power	0,87	excl. O&M
Wind power	0,28	incl. O&M
Pumped storage (net hydropower)	1,07	incl. O&M
Wind power + pumped storage	0,4	incl. O&M

Source: Jarðfeingi, Ea Energy Analysis based on Norconsults report and information from SEV

Conclusion: price for production with pumped storage+wind is comparable to heavy fuel based power!

# **Alternatives?**





Connecting the wind turbines only to the pumped storage plant, which again is connected to the grid is theoretically possible.

In order to get the same net energy (due to the loss of energy though pumping), it would be necessary to install more wind turbines (14 MW). In addition, a larger pumped storage plant would be needed (14 MW pumps and 10 MW turbine). This possibility has not been studied.



Cable: it is not certain that a cable to the main grid is needed. → Check before taking for given!



Figure: SEV



Adapt consumption?

➡ Possibilities to reduce consumption in short periods should be studied (smart grid approach).

→ Useful in combination with wind power production.



# **Thank you for your attention!**



